
TEST REPORT n. 4920/2020/I

CERAMIC TILES - DETERMINATION OF RESISTANCE TO THERMAL SHOCK

UNI EN ISO 10545-9: 2014

Date of report:	12/04/2020
Customer:	NUOVOCORSO S.p.A. Via Mulini Valle Tresinaro, 11 42033 ZOCCADELLO DI ONFIANO - CARPINETI (RE)
Requested on:	11/04/2020
Our ref.number:	28787
Execution place of tests:	Scandiano (RE)
Description of the sample:	"Portion of ceramic tiles glazed 60x60 cm obtained by cutting to original size 160x320 cm marked: GLAZED PORCELAIN TILES RECTIFIED"
Sampling:	carried out by the customer
Receipt date of samples:	11/04/2020
Execution date of tests:	start: 11/30/2020 end: 12/01/2020
Test specification:	UNI EN ISO 10545 - 9:2014 Determination of resistance to thermal shock
Warnings:	<i>This test report can not be reproduced in part, without our written consent. The reported results relate only to the samples tested. The information included in quotation marks was provided by the customer.</i>

TEST REPORT n. 4920/2020/I

CERAMIC TILES - DETERMINATION OF RESISTANCE TO THERMAL SHOCK

UNI EN ISO 10545-9: 2014

Principle: Determination of the resistance to thermal shock of a whole tile by cycling 10 times between the temperature of 15°C and 145 °C.

Test results:

N. samples tested:	5
Average percentage water absorption :	0,5
Type of test performed:	with immersion
Number of tiles with visible defects:	0



THE DIRECTOR
(G.Gaido)

End of the document
