
TEST REPORT n. 4766/2020/I
CERAMIC TILES - DETERMINATION OF WATER ABSORPTION
UNI EN ISO 10545-3: 2018

Date of report: 11/26/2020

Customer: **NUOVOCORSO S.p.A.**

Via Mulini Valle Tresinaro, 11
42033 ZOCCADELLO DI ONFIANO - CARPINETI (RE)

Requested on: 11/13/2020

Our ref.number: 28902

Execution place of tests: Scandiano (RE)

Description of the sample: "Ceramic tiles glazed 160x320 cm
marked: GLAZED PORCELAIN TILES RECTIFIED"

Sampling: carried out by the customer

Receipt date of samples: 11/16/2020

Execution date of tests: start: 11/23/2020 end: 11/24/2020

Test specification: UNI EN ISO 10545 - 3:2018
Determination of water absorption

Warnings: *This test report can not be reproduced in part, without our written consent.
The reported results relate only to the samples tested.
The information included in quotation marks was provided by the customer.*

TEST REPORT n. 4766/2020/I
CERAMIC TILES - DETERMINATION OF WATER ABSORPTION
UNI EN ISO 10545-3: 2018

Principle: Impregnation of dry tiles dried and calculation their water absorption E_v .

N. samples tested: 5

Note: the test has been executed on the only 5 samples submitted to Laboratory by Client.

Sample size: before preparation: 320x160 cm after: 20x20 cm

Test results: 1) Water absorption E_v (%):

n. sample	E_v (%)
1	0,1
2	0,1
3	0,2
4	0,1
5	0,2

2) Water absorption mean value E_v (%): 0,1



The Director
Giulia Gaido

End of the document
